



NAMEPLATE



Class I Div 2, Grps A-D, Type 4X
 Ex nA nC IIC T6 Gc; IP65
 -40°C ≤ Ta ≤ 50°C
 BUS: Max Current 500mA @ Max Voltage 25VDC
 PILOT: 24 VDC

Telemetering Equipment for use In Hazardous Locations
WARNING: Substitution of components may impair suitability for use in Class I, Division 2 or Zone 2 environments. Must be known to be non-hazardous area before servicing. Clean only with damp cloth.
AVERTISSEMENT: La substitution de composants peut altérer l'aptitude pour une utilisation dans Classe I, Division 2 environnements. Doivent être connus pour être des zones non dangereuses avant l'entretien.

TopWorX
 3300 Fern Valley Road
 Louisville, KY 40213 USA
 www.topworx.com



DXP-DN20NEB2A2

Switchbox DXP and DXS

Equipment Identification
 Part Number: DXP-DN20NEB2A2
 Rev. Number: 0001
 Date: 08/20/10
 Drawing Number: 0001
 Drawing Date: 08/20/10
 Drawing Description: DXP-DN20NEB2A2
 Drawing Scale: 1:1
 Drawing Unit: INCHES
 Drawing Format: PDF
 Drawing Status: RELEASED
 Drawing Author: J. B. BROWN
 Drawing Checker: J. B. BROWN
 Drawing Approver: J. B. BROWN

MODEL NUMBER

PRODUCT LINE

SPECIFICATIONS

WIRING DIAGRAM



www.electrosupply.com
sales@electrosupply.com
 1-800-663-6576