



MODEL NUMBER

PRODUCT LINE

SPECIFICATIONS

WIRING DIAGRAM

NAMEPLATE



CI I Div 1, Grps C-D; Type 4X
 Ex d IIB + H₂ T6 Gb; IP66/67
 -50 C ≤ T_a ≤ 60 C
 SIRA 07ATEX1273X IECEX SIR 07.0093X
 SWITCH: DPDT 15A/125VAC
 4-20mA LOOP: 8.5 to 34VDC, 20mA

Telemetering Equipment for use in Hazardous Locations
WARNING: Disconnect the power before servicing. Keep tightly closed during operation. Must be known to be non-hazardous area before servicing. Clean only with damp cloth.
AVERTISSEMENT: Débranchez l'alimentation avant l'entretien. Conserver hermétiquement fermé pendant le fonctionnement. Doivent être connus pour être des zones non dangereuses avant l'entretien.

TopWork
 3300 Fern Valley Road
 Louisville, KY 40213 USA
 www.topwork.com

Model #:

Serial #:

DXP-TX1GNEB

Switchbox DXP and DXS

Equipment: TopWork
 Rev. Number: 1/2008
 Date: 1/2008
 Drawn: J. Smith
 Checked: J. Smith
 Approved: J. Smith
 Part Number: 07ATEX1273X
 Description: Switchbox DXP and DXS

Electrol

www.electrosupply.com
 sales@electrosupply.com
 1-800-663-6576