

no longer available - archive entry


efectorno[®]

G1506S



Evaluation unit,asi

Safety technology



1: label

2: fixture infrared adapter



Product characteristics

Evaluation unit for fail-safe sensors

AS-i interface to FC/FC-E lower parts

Sockets M12 x 1

AS-i version 2.1

IR addressing possible

Category 4 in accordance with EN 954-1

-

For the connection of 1 chain with up to 8 fail-safe sensors

Other data

Data sheet: see operating instructions

Original operating instructions, (German, Spanish, French, Italian, Swedish, English)

Remark concerning other language versions

ifm efector, inc. • 1100 Atwater Drive • Malvern • PA 19355 — US — G1506S — 24.07.2008

no longer available - archive entry